

**Town of Mammoth AZ04-11-018**  
**Distribution System Lead and Copper Sampling - Triennial Compliance (Reduced Sampling)**  
**Aug-11**

Address	#	Bottle Dropped Off	Sample Date	Copper Analysis Date	Copper (mg/l)	Action Level (mg/l)
737 Tiger Drive #3	1	8/1/2011	8/2/2011	8/10/2011	0.006	
705 Dungan Dr	2	8/1/2011	8/2/2011	8/10/2011	0.007	
725 N Cliff Street	3	8/1/2011	8/2/2011	8/10/2011	0.026	
600 San Manuel Dr	4	8/1/2011	8/2/2011	8/10/2011	0.027	
111 E Hayden Ave	5	8/1/2011	8/3/2011	8/10/2011	0.033	
102 Owens Place #14	6	8/1/2011	8/2/2011	8/11/2011	0.061	
419 Hetzel Ave	7	8/1/2011	8/2/2011	8/11/2011	0.067	
500 Rolfs Ave	8	8/1/2011	8/2/2011	8/11/2011	0.13	
201 Catalina Ave	9	8/1/2011	8/3/2011	8/10/2011	0.30	
802 Arthur Place	10	8/1/2011	8/2/2011	8/11/2011	0.55	
732 N. Old Hwy 77	11	8/1/2011	8/3/2011	8/10/2011	0.59	1.3
14930 S. Hwy 77 #1	12	8/1/2011	8/2/2011	8/10/2011	0.98	
<b>90<sup>th</sup> Percentile</b>					<b>0.59</b>	<b>1.3</b>

Address	#	Bottle Dropped Off	Sample Date	Lead Analysis Date	Lead (mg/l)	Action Level (mg/l)
737 Tiger Drive #3	1	8/1/2011	8/2/2011	8/9/2011	ND	
802 Arthur Place	2	8/1/2011	8/2/2011	8/11/2011	ND	
705 Dungan Dr	3	8/1/2011	8/2/2011	8/9/2011	ND	
500 Rolfs Ave	4	8/1/2011	8/2/2011	8/11/2011	0.00059	
600 San Manuel Dr	5	8/1/2011	8/2/2011	8/9/2011	0.00064	
725 N Cliff Street	6	8/1/2011	8/2/2011	8/9/2011	0.00079	
201 Catalina Ave	7	8/1/2011	8/3/2011	8/9/2011	0.0016	
732 N. Old Hwy 77	8	8/1/2011	8/3/2011	8/9/2011	0.0016	
102 Owens Place #14	9	8/1/2011	8/2/2011	8/11/2011	0.0026	
111 E Hayden Ave	10	8/1/2011	8/3/2011	8/9/2011	0.0057	
14930 S. Hwy 77 #1	11	8/1/2011	8/2/2011	8/9/2011	0.0097	0.015
419 Hetzel Ave	12	8/1/2011	8/2/2011	8/11/2011	0.025	
<b>90<sup>th</sup> Percentile</b>					<b>0.0097</b>	<b>0.015</b>

Action Level for Lead = 0.015 mg/l    Action Level for Copper = 1.3 mg/l

90th Percentile is Highlighted in Yellow

The Town of Mammoth is a Small System serving 501 - 3,300 people.

The Town of Mammoth qualifies for reduced sampling and is required to take 10 samples.

**The drinking water in the Town of Mammoth did not exceed the Action Levels for Copper or Lead in 2011.**